



— Township of —

**SEVERN**

Water Supply and Distribution System

# **Bass Lake Woodlands 2020 Annual Report**



ANNUAL REPORT

<b>Drinking-Water System Number:</b>	220005143
<b>Drinking-Water System Name:</b>	Bass Lake Woodlands Water Supply and Distribution
<b>Drinking-Water System Owner:</b>	The Corporation of the Township of Severn
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2020 to December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;">       Township of Severn Administrative Office        1024 Hurlwood Lane        Severn, Ontario        L3V 0Y6     </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
---	--

**Note: For the following tables below, additional rows or columns may be added, or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [ ] No [ ]



Indicate how you notified system users that your annual report is available and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

Water for Bass Lake Woodlands comes from three (3) ground water wells located at 1852 Ridley Boulevard. Groundwater is pumped from the well into the pump house where it is chlorinated using sodium hypochlorite. It then travels through a 32 m<sup>3</sup> chlorine contact tank before being stored in a 136 m<sup>3</sup> underground reservoir. Treated water is pumped from the reservoir by three VFD-controlled vertical turbine high lift pumps to the distribution system. The distribution system is comprised of 150 mm PVC water main with copper and PE service lines to the homes. There are four (4) sample stations and three (3) blow-offs located throughout the distribution system. There are no fire hydrants. The system services approximately 450 residents of the community Bass Lake Woodlands.

**List all water treatment chemicals used over this reporting period.**

Sodium Hypochlorite

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred.**

High lift Pump #2 Rebuild-\$25,000.00.

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A					



**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw – Well #1	52	0 - 0	0 – 0	N/A	-
Raw – Well #2	53	0 - 0	0 – 1	N/A	-
Raw – Well #3	52	0 - 0	0 – 0	N/A	-
Treated	52	0 – 0	0 – 0	52	0-10
Distribution	104	0 - 0	0 - 0	53	0 - 10

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity – Well #1	12	0.46 – 0.97 NTU
Turbidity – Well #2	12	0.26 – 0.77 NTU
Turbidity – Well #3	12	0.04 – 0.29 NTU
Turbidity	8760	0.06 – 0.70 NTU
Chlorine	8760	0.87 – 1.12
Chlorine Free Residual Distribution System	367	0.56 – 1.08
Fluoride (If the DWS provides fluoridation)	N/A	

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results.**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	October 26, 2020	0.09	µg/L	No
Arsenic	October 26, 2020	0.2	µg/L	No
Barium	October 26, 2020	226	µg/L	No
Boron	October 26, 2020	2	µg/L	No
Cadmium	October 26, 2020	0.003	µg/L	No



<b>Chromium</b>	October 26, 2020	0.96	µg/L	No
<b>*Lead</b>	Jan 27,2020-July 27, 2020	0.05-0.09		
<b>Mercury</b>	October 26, 2020	0.01	µg/L	No
<b>Selenium</b>	October 26, 2020	0.14	µg/L	No
<b>Sodium</b>	October 26, 2020	50.4	mg/L	Yes
<b>Uranium</b>	October 26, 2020	0.231	µg/L	No
<b>Fluoride</b>	October 26, 2020	0.08	mg/L	No
<b>Nitrite</b>	January 27, 2020 April 27, 2020 July 27, 2020 Oct. 26, 2020	0.003 0.003 0.003 0.003	mg/L	No
<b>Nitrate</b>	January 27, 2020 April 27, 2020 July 27, 2020 Oct. 26, 2020	1.60 1.76 1.58 1.77	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

<b>Location Type</b>	<b>Number of Samples</b>	<b>Range of Lead Results (min#) – (max #)</b>	<b>Number of Exceedances</b>
<b>Plumbing</b>	N/A		
<b>Distribution</b>	2	0.05-0.09	NO

**Summary of Organic parameters sampled during this reporting period or the most recent sample results.**

<b>Parameter</b>	<b>Sample Date</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
<b>Alachlor</b>	October26,2020	0.02	µg/L	No
<b>Atrazine + N-dealkylated metobolites</b>	October26,2020	0.01	µg/L	No
<b>Atrazine</b>	October26,2020	0.01	µg/L	No
<b>Azinphos-methyl</b>	October26,2020	0.05	µg/L	No
<b>Benzene</b>	October26,2020	0.32	µg/L	No
<b>Benzo(a)pyrene</b>	October26,2020	0.004	µg/L	No
<b>Bromoxynil</b>	October26,2020	0.33	µg/L	No
<b>Carbaryl</b>	October26,2020	0.05	µg/L	No
<b>Carbon tetrachloride</b>	October26,2020	0.17	µg/L	No
<b>Carbofuran</b>	October26,2020	0.01	µg/L	No
<b>Chlorpyrifos</b>	October26,2020	0.02	µg/L	No
<b>Diazinon</b>	October26,2020	0.02	µg/L	No
<b>Dicamba</b>	October26,2020	0.20	µg/L	No



1,2-Dichlorobenzene	October26,2020	0.41	µg/L	No
1,4-Dichlorobenzene	October26,2020	0.36	µg/L	No
1,2-Dichloroethane	October26,2020	0.35	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	October26,2020	0.33	µg/L	No
Dichloromethane	October26,2020	0.35	µg/L	No
2-4 Dichlorophenol	October26,2020	0.15	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	October26,2020	0.19	µg/L	No
Diclofop-methyl	October26,2020	0.40	µg/L	No
Dimethoate	October26,2020	0.06	µg/L	No
Diquat	October26,2020	<1	µg/L	No
Diuron	October26,2020	0.03	µg/L	No
Glyphosate	October26,2020	1	µg/L	No
Haloacetic Acids (HAA5) (NOTE: show latest annual average)	2020 Average	<5.3	µg/L	No
Malathion	October26,2020	.02	µg/L	No
Metolachlor	October26,2020	0.01	µg/L	No
Metribuzin	October26,2020	0.02	µg/L	No
MCPA	October26,2020	0.00012	mg/L	No
Monochlorobenzene	October26,2020	0.3	µg/L	No
Paraquat	October26,2020	<1	µg/L	No
Pentachlorophenol	October26,2020	0.15	µg/L	No
Phorate	October26,2020	0.01	µg/L	No
Picloram	October26,2020	<1	µg/L	No
Polychlorinated Biphenyls (PCB)	October26,2020	0.04	µg/L	No
Prometryne	October26,2020	0.03	µg/L	No
Simazine	October26,2020	0.01	µg/L	No
THM (NOTE: show latest annual average)	2020 Average	7.80	µg/L	No
Terbufos	October26,2020	0.01	µg/L	No
Tetrachloroethylene	October26,2020	0.35	µg/L	No
2,3,4,6-Tetrachlorophenol	October26,2020	0.20	µg/L	No
Triallate	October26,2020	0.01	µg/L	No
Trichloroethylene	October26,2020	0.44	µg/L	No
2,4,6-Trichlorophenol	October26,2020	0.25	µg/L	No
Trifluralin	October26,2020	0.02	µg/L	No
Vinyl Chloride	October26,2020	0.17	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium	50.4	mg/L	October 26, 2020