



— Township of —

SEVERN

Water Supply and Distribution System
Coldwater
2023 Summary Report

Contents

- Overview and Background 3**
 - Safe Drinking Water Act3
 - Municipal Drinking Water Licensing Program3
 - System and Process Description4
 - Source Water.....4
 - Raw Water Characteristics4
 - Water Treatment.....5
 - Water Distribution.....5
- Regulatory Compliance 5**
 - Regulations5
 - Ontario Regulation 170/03..... 6
 - Ontario Regulation 169/03..... 6
 - Ontario Regulation 128/04..... 6
 - Wells Regulation 903 6
 - Drinking Water Quality Management Standard (DWQMS)..... 6
 - Municipal Drinking Water License 7
 - Drinking Water Works Permit License..... 7
 - Non-Compliance and Adverse Water Quality Incidents.....7
 - DWQMS and Municipal Drinking Water Licensing Program7
 - Third-Party Audit and Accreditation 7
 - Internal Audit..... 8
 - Management Review..... 8



Annual Operations Summary	8
System Improvements and Maintenance	8
Microbiological Testing.....	9
E. Coli and Total Coliform	9
Heterotrophic Plate Count (HPC)	9
Chlorine Residual and Turbidity.....	10
Chemical Testing.....	10
Understanding Chemical Test Results.....	11
Water Quantity	14
Summary of Raw Water Flows	14
Summary of Distribution Flows	15
Flow Charts.....	16
Appendix A	17
Common Acronyms	17
Regulatory and Compliance.....	17
Parameters and Measurements.....	18
Facilities and Training/Licensing	18
Other	19

Overview and Background

Safe Drinking Water Act

Safe Drinking Water Act Ontario Regulation 170/03, Schedule 22-2, requires that owners of municipal drinking water systems prepare a Summary Report and present this report to the members of Municipal Council by March 31 of each year. The report is prepared for the previous calendar year and the following criteria must be included as per the regulation:

- List the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and orders applicable to the system that were not met during the period covered by the report.
- For each requirement referred to in clause (a) that was not met specify the duration of the failure and the measures that were taken to correct the failure.
- A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
- A comparison of the summary referred to in (c) to the rated capacity and flow rates approved by the system's certificate of approval, drinking water works permit or municipal drinking water license.

This Summary Report also serves as a comprehensive review of the systems performance as it relates to regulations and criteria that fall under the municipal drinking water licensing program.

Municipal Drinking Water Licensing Program

A Municipal Drinking Water License (MDWL) is required in Ontario to operate the drinking water system. The Municipal Drinking Water License (#148-101 Issue Number 3) was re-issued on May 20, 2021 and is valid until May 19, 2026. The reissuance was initiated by the Ministry of Environment, Conservation and Parks



(MECP) due to regulatory amendments that required timelines to be outlined in the MDWL. There are five requirements that must be achieved to obtain an MDWL:

- a valid Drinking Water Works Permit (#148-201 Issue Number 3)
- a valid Permit to Take Water for each source (#06005-8ZSPHN)
- an Operational Plan
- must have an Accredited Operating Authority (C0124837-DWQ4-C0122097)
- a Financial Plan approved by Council

System and Process Description

The Corporation of the Township of Severn is the owner and operator of the Coldwater Water Supply and Distribution System (DWS# 220001110). It currently has 591 residential and commercial service connections. It also supplies water to Riverwalk Estates distribution system that is comprised of 46 connections. Coldwater is classified as a Class 1 Water Treatment system and a Class 1 Water Distribution system.

Source Water

The Coldwater Water Supply and Distribution System obtains its raw water from any one of two (2) 200mm diameter drilled wells (Well 1 & 3) located on the pump house property or from a 150mm diameter drilled well (Well 2) located across the street from the pump house.

Raw Water Characteristics

The raw water is of low turbidity and is of acceptable ph. Due to the depth of the source water the temperature is relatively constant.

Water Treatment

Water entering the pump house is partially softened with a Kinetico water softener and then filtered using two Calgon model 8 GAC filters operated in series. Filtered water is then disinfected using sodium hypochlorite. Treated water is then stored in an underground reservoir.

Water is pumped to the distribution system via three vertical turbine high lift pumps. A fire pump is also installed to provide adequate flow in the event of a fire. Pressure in the distribution system is maintained at approximately 65 pounds-per-square-inch (PSI) by five 450 litre (L) pressure tanks.

Online analyzers monitor and record raw and treated water flow rates, treated water turbidity, free chlorine residual and pH. Level sensing probes record well levels. The plant is also equipped with full SCADA control.

Standby power is provided to the building and all its equipment by a 250 kilowatt (kW) standby diesel generator.

Water Distribution

The distribution system is comprised of 8.9 kilometres (km) of water main ranging in size from 50 millimetre (mm) to 300 mm. There are 10 sample stations, 5 blow-offs, 83 fire hydrants and 3 private hydrants in the Coldwater system.

Regulatory Compliance

Regulations

All municipally owned and operated water systems are governed under the Safe Drinking Water Act, 2002, Ontario Water Resources Act (OWRA), and associated regulations. The following regulations, and associated standards and documents, are all applicable, and most relevant, to the compliant operation of the Township of Severn's Drinking Water system:



Ontario Regulation 170/03

This regulation includes requirements for:

- Sampling and analytical testing (microbiological and chemical)
- Adverse water quality incidents
- Corrective actions
- Continuous water quality monitoring

Ontario Regulation 169/03

This regulation includes requirements for:

- Water Quality Standards

Ontario Regulation 128/04

This regulation includes requirements for:

- Classifications of Drinking Water Systems
- Certifications and responsibilities of Operators
- Proper record keeping of the drinking water system

Wells Regulation 903

This regulation includes requirements for:

- Well maintenance
- Well specifications

Drinking Water Quality Management Standard (DWQMS)

This Standard specifies:

- Minimum requirements for the Quality Management System to allow for the accreditation of the Operating Authority



Municipal Drinking Water License

This document includes requirements for:

- Specific conditions / testing / monitoring
- Flow limits through the treatment system
- Regulatory relief conditions
- Operations and Maintenance manual criteria

Drinking Water Works Permit License

This document includes criteria for:

- Making alterations to the system

Non-Compliance and Adverse Water Quality Incidents

There were (2) two adverse water quality incidents in 2023.

- Coldwater has a five-year reporting period for sodium. Sodium lab results of 98.6 mg/L exceeded the limit of 20 mg/L.
- July 26, 2023, had a lab result of 47 Total coliform and 27 E-coli. System was resampled with no detection of total coliform or E. coli.

DWQMS and Municipal Drinking Water Licensing Program

Third-Party Audit and Accreditation

On an annual basis, a third-party accreditation authority conducts an audit to determine whether the Quality Management System conforms to the requirements of the MECP Drinking Water Quality Management Standard (DWQMS).

From October 11 to 13, 2023. NSF International completed an onsite audit with no corrective actions required.



Internal Audit

As per the DWQMS, an internal audit is to be conducted once per year. September 1, 6, and 7, 2023, an internal audit was conducted by Acclains Environmental. The findings were included during Management Review.

Management Review

As per the DWQMS, an annual Management Review is to be conducted and findings conveyed to the Owner. Management Reviews were conducted February 15, 2023, and August 29, 2023. The review included findings from the internal and external audits, MECP inspections and other prescribed items.

Annual Operations Summary

System Improvements and Maintenance

The following maintenance and improvements were carried out in 2023 to provide the highest possible drinking water quality:

- The water distribution system was directionally flushed to maintain the drinking water quality.
- Over 25 per cent of the main valves in the distribution system were exercised to ensure their reliability.
- The standby generator was tested under load monthly to ensure reliability.
- All critical alarms were tested monthly to ensure reliability.
- Drinking water quality was tested at the water treatment plant and in the distribution system weekly.
- New GAC media installed.
- New turbidity analyzer.
- New metal roof.

Microbiological Testing

E. Coli and Total Coliform

Bacteriological samples, to be tested for E. Coli and Total Coliforms, are taken weekly from the raw and treated water at the facility and from the distribution system. Extra samples are taken after major repairs or maintenance work as per Regulation 170/03. Any E. Coli or Total Coliform results above 0 in treated water must be reported to the MECP and Medical Officer of Health (MOH). Resamples and other required actions are undertaken as quickly as possible.

The results from the 2023 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of E-Coli Results (cfu/100ml) (Min - Max) MAC=0	Range of Total Coliform Results (cfu/100ml) (Min - Max) MAC=0
Raw	157	0 - 0	0 - 1
Treated	210	0 - 27	0 - 47

Heterotrophic Plate Count (HPC)

HPC analyses are completed weekly from the distribution water for large systems. HPC should be less than 500 colonies (cfu) per 1mL. Results over 500 colonies (cfu) per 1 mL may indicate a change in water quality but it is not considered an indicator of unsafe water.

The results from the 2023 sampling program are shown on the table below.

Type of Water	Number of Samples	Range of HPC Results (cfu/1ml) (Min - Max)
Distribution	156	0 - 840

Chlorine Residual and Turbidity

Free chlorine levels of the treated water are monitored continuously at the discharge point of the treatment facility. In the distribution system, free chlorine is checked twice weekly at various locations. As a target, free chlorine residual within the distribution system should be above 0.20 mg/L. A free chlorine level lower than 0.05 mg/L must be reported to the MECP and corrective action taken. There were no reportable incidents in 2023. The results from the 2023 sampling program are shown on the table below.

Turbidity of treated water is continuously monitored at the treatment facility, as a change in turbidity can indicate an operational problem. Turbidity of the wells are checked monthly. Turbidity is measured in Nephelometric Turbidity Units (NTU).

The results from the 2023 sampling program are shown on the table below.

Parameter	Number of Tests	Range of Results (Min - Max) Average
Chlorine residual in distribution (mg/L)	364	(0.94 - 1.48) 1.23
Chlorine residual after treatment (mg/L)	Continuous	(1.17 - 1.51) 1.32
Turbidity after treatment (NTU)	Continuous	(0.10 - 0.68) 0.38

Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for different chemical parameters. The latest results are provided below. The sampling frequency varies for different types and sizes of water systems and chemical parameters. If the concentration of a parameter is above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by the Regulation. Where concerns regarding a parameter exist, the MECP can also require additional sampling. Information on the health effects and allowable limits of components in drinking water may be found on the MECP web page.

Understanding Chemical Test Results

Tables below are shown with concentrations units of either milligrams per litre (mg/L) or micrograms per litre ($\mu\text{g/L}$): 1 mg/L is equal to 1000 $\mu\text{g/L}$. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. A result of “ND” stands for “Not Detected” and means that the concentration of the chemical is lower than the laboratory’s equipment is capable of measuring.

Nitrate and Nitrite samples are required every 3 months in normal operation.

Parameter	Result Range Min - Max	Average	MAC (mg/L)	MDL (mg/L)
Nitrite (mg/L)	0.003 - 0.003	0.003	1	0.003
Nitrate (mg/L)	0.006- 0.006	0.006	10	0.006

A Trihalomethane (THM) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC ($\mu\text{g/L}$)	MDL ($\mu\text{g/L}$)
THM	2023	9.19	100	0.37

A Haloacetic Acid (HAA) sample is required every 3 months from the distribution system.

Parameter	Annual	Result (Avg.)	MAC ($\mu\text{g/L}$)	MDL ($\mu\text{g/L}$)
HAA	2023	< 5.3	80	5.3



Summary of the most recent sodium, fluoride and hardness results.

Parameter	Sample Date	Result (mg/L)	MAC (mg/L)	MDL (mg/L)
Sodium	2023	98.6	20	0.01
Fluoride	2023	0.12	1.5	0.06
Hardness	2023	319	N/A	0.05

Summary of the most recent lead testing results.

Parameter	Sample Date	Result Range (Min - Max)	Number of samples	Acceptable Level
Distribution Alkalinity	2023	232 - 237 mg/L	2	30-500 mg/L
Distribution pH	2023	7.7 - 8.2	2	6.5-8.5
Distribution Lead	2023	0.04 - 0.05 µg/L	2	10 µg/L

Summary of the most recent Schedule 23/24 testing as per Regulation 170/03

*All results are measured in µg/L unless otherwise stated.

Parameter	Sample Date	Result Value	MAC	MDL
Antimony	Oct. 23, 2023	0.6	6	0.6
Arsenic	Oct. 23, 2023	0.2	10	0.2
Barium	Oct. 23, 2023	279	1000	0.02
Boron	Oct. 23, 2023	46	5000	2
Cadmium	Oct. 23, 2023	0.003	5	0.003
Chromium	Oct. 23, 2023	0.15	50	0.08
Mercury	Oct. 23, 2023	0.01	1	0.01
Selenium	Oct. 23, 2023	0.04	50	0.04
Uranium	Oct. 23, 2023	0.900	20	0.002
Benzene	Oct. 23, 2023	0.32	1	0.32
Carbon tetrachloride	Oct. 23, 2023	0.17	2	0.17
1,2-Dichlorobenzene	Oct. 23, 2023	0.41	200	0.41
1,4-Dichlorobenzene	Oct. 23, 2023	0.36	5	0.36
1,1-Dichloroethylene	Oct. 23, 2023	0.33	14	0.33

Parameter	Sample Date	Result Value	MAC	MDL
1,2-Dichloroethane	Oct. 23, 2023	0.35	5	0.35
Dichloromethane	Oct. 23, 2023	0.35	50	0.35
Monochlorobenzene	Oct. 23, 2023	0.30	80	0.3
Tetrachloroethylene	Oct. 23, 2023	0.35	10	0.35
Trichloroethylene	Oct. 23, 2023	0.44	5	0.44
Vinyl Chloride	Oct. 23, 2023	0.17	1	0.17
Bromoform	Oct. 23, 2023	1.6	--	0.34
Diquat	Oct. 23, 2023	1	70	1
Paraquat	Oct. 23, 2023	1	10	1
Glyphosate	Oct. 23, 2023	1	280	1
PCBs	Oct. 23, 2023	0.04	3	0.04
Benzo(a)pyrene	Oct. 23, 2023	0.004	0.01	0.004
Bromodichloromethane	Oct. 23, 2023	0.80		0.29
Bromoacetic Acid	Oct. 23, 2023	2.9		2.9
Alachlor	Oct. 23, 2023	0.02	5	0.02
Azinphos-methyl	Oct. 23, 2023	0.05	20	0.05
Carbaryl	Oct. 23, 2023	0.05	90	0.05
Carbofuran	Oct. 23, 2023	0.01	90	0.01
Chlorpyrifos	Oct. 23, 2023	0.02	90	0.02
Chloroform	Oct. 23, 2023	0.29		0.29
Chloroacetic Acid	Oct. 23, 2023	4.7		4.7
Diazinon	Oct. 23, 2023	0.02	20	0.02
Dimethoate	Oct. 23, 2023	0.06	20	0.06
Diuron	Oct. 23, 2023	0.03	150	0.03
Dibromoacetic Acid	Oct. 23, 2023	2.0		2.0
Dibromochloromethane	Oct. 23, 2023	2.0		0.37
Dichloroacetic Acid	Oct. 23, 2023	2.6		2.6
Malathion	Oct. 23, 2023	0.02	190	0.02
Metolachlor	Oct. 23, 2023	0.01	50	0.01
Metribuzin	Oct. 23, 2023	0.02	80	0.02
Phorate	Oct. 23, 2023	0.01	2	0.01
Prometryne	Oct. 23, 2023	0.03	1	0.03
Pentachlorophenol	Oct. 23, 2023	0.15	60	0.15


Parameter	Sample Date	Result Value	MAC	MDL
Simazine	Oct. 23, 2023	0.01	10	0.01
Terbufos	Oct. 23, 2023	0.01	1	0.01
Triallate	Oct. 23, 2023	0.01	230	0.01
Trifluralin	Oct. 23, 2023	0.02	45	0.02
2,4-dichlorophenoxyacetic acid	Oct. 23, 2023	0.19	100	0.19
Bromoxynil	Oct. 23, 2023	0.33	5	0.33
Dicamba	Oct. 23, 2023	0.20	120	0.20
Dichlofop-methyl	Oct. 23, 2023	0.40	9	0.40
MCPA (mg/L)	Oct. 23, 2023	0.00012	0.1	0.00012
Picloram	Oct. 23, 2023	<1	190	1
2,4,6-trichlorophenol	Oct. 23, 2023	0.25	5	0.25
2,3,4,6-tetrachlorophenol	Oct. 23, 2023	0.20	100	0.20
Trichloroethylene	Oct. 23, 2023	.44	5	.44

Water Quantity

Continuous monitoring of flow rates from supply wells into the treatment system and from the facility into the distribution system is required by Regulation 170/03. The Municipal Drinking Water License and Permit to Take Water issued by the MECP regulate the amount of water that can be utilized over a given time. A summary of the 2023 flows is provided in the tables below.

Flow Summary	Quantity
Permit to Take Water Limit	Well 1 - 2141 m ³ /day Well 2 - 982.37 m ³ /day Well 3 - 982.37 m ³ /day
Total Taking Limit	2141m ³ /day
Municipal Drinking Water License Limit	3128m ³ /day
2023 Average Daily Flow	364 m ³
2023 Maximum Daily Flow	771 m ³
2023 Total Amount of Water Supplied	132789 m ³

Summary of Raw Water Flows





Month	Well #1 (m ³)	Well #2 (m ³)	Well #3 (m ³)
January	13663	45	51
February	12010	42	45
March	13171	43	48
April	12526	47	51
May	14321	39	54
June	15955	43	47
July	15304	51	58
August	14122	44	53
September	13905	35	34
October	13084	57	59
November	12195	38	42
December	12793	47	50
TOTAL	163050		

Summary of Distribution Flows

Month	Monthly Total (m ³)	Average Daily Flow (m ³ /day)	Minimum Daily Flow (m ³ /day)	Maximum Daily Flow (m ³ /day)
January	11075	357	262	771
February	9686	346	263	576
March	10613	342	239	463
April	10195	340	235	449
May	11716	378	273	534
June	13026	434	308	619
July	12578	406	285	586
August	11622	375	259	481
September	11346	378	277	450
October	10623	343	239	461
November	9973	332	255	392
December	10337	333	221	410
Total	132789			

Flow Charts

*Note all values are in (m³)



Appendix A

Common Acronyms

Regulatory and Compliance

MECP	Ministry of Environment, Conservation and Parks (<i>formerly Ministry of the Environment</i>)
DWQMS	Drinking Water Quality Management System
QMS	Quality Management System
PTTW	Permit to Take Water
MDWL	Municipal Drinking Water License
DWWP	Drinking Water Works Permit
C of A	Certificate of Approval
DWS	Drinking Water System
AWQI	Adverse Water Quality Incident
BWA	Boil Water Advisory
ORO	Overall Responsible Operator
OIC	Operator in Charge
OFI	Opportunity for Improvement
BMP	Best Management Practices

Parameters and Measurements

ppm	parts per million
mg/L	milligrams per litre
µg/L	micrograms per litre
mj/cm²	millijoule per square centimeter
psi	pounds per square inch
w/m²	watt per square meter
THM	Trihalomethane
HAA	Haloacetic Acid
UV	Ultra Violet
CCP	Critical Control Point

Facilities and Training/Licensing

OWWCO	Ontario Water Wastewater Certification Office
WCWC	Walkerton Clean Water Centre
OIT	Operator in Training
WTP	Water Treatment Plant
CEU	Credited Education Units

Other

GAC	Granular Activated Carbon
VFD	Variable Frequency Drive
HL	High Lift (pump)
SCADA	Supervisory Control and Data Acquisition
LL	Low Lift (pump)